

## MEMORANDUM

PA 90-A  
5-63

REFER		NOTE	
TO	DATE	BY	DATE
RETURN TO		FILE	

TO: Mr. Robert J. Linn, Manager, Project Planning, WTC  
 FROM: Joseph Milano  
 DATE: April 13, 1970  
 SUBJECT: THE WORLD TRADE CENTER - TELCO - FIREPROOFING

REFERENCE: 1) Memo, Linn to Milano, dated 3-25-70. 2) Change Number 730.003. Add. #1.

COPY TO: Messrs. P. Goz, T. Kearney, M. Levy, C. Lynch, J. McAvey, G. Marx, M. Morrow,  
 J. Schwartzman (all w/att.)

230-36

The attached letter from New York Telephone, E. Warter to G. Marx, dated April 7, 1970, mentions their concern in reference to the "special" fireproofing for the trusses in the ceilings of Floors 10, 11 and 12 of Tower B.

Telco's comments and requests are:

- Before authorization of the fireproofing, Telco requires a review of the portion of our contract dealing with the "special" fireproofing and an inspection of a field sample.
- The samples, as transmitted in the referenced memo, are unsatisfactory. The fireproofing is to be applied by conventional method and then compressed by manual tamping or troweling and sealed with the Mark II Overspray.
- Arrange to have a sample installation of the actual fireproofing on a typical Telco truss or similar type truss.

GOZ  
OBTAINING INFOChange #  
730.003  
Add #2

FU-5/11

FU-6/8

Attachment

js



J. Milano

Joseph Milano  
 Project Administrator  
 Special Programs Division  
 The World Trade Center

See ~~Memo~~ Letter

Memo to DiBano 6/5/70